

TFT

(Ilkley) Ltd.

The Sidings Business Park, SKIPTON, North Yorkshire, BD23 1TB
Phone or Fax 01756 792525

Office: 30 Alexandra Crescent, ILKLEY, West Yorkshire, LS29 9ER, Phone or Fax 01943 603459

Reg. No. 3168606, VAT No. 659 9604 77



TEST CERTIFICATE

No. 05320/2

Assessment to BS 5867 : 1980 Specification for Fabrics for
Curtains and Drapes, Part 2 : Flammability Requirements using BS 5438 : 1976

SAMPLE INFORMATION

Client Custom Covers (1984) Ltd., Quayside Road, Bitterne Manor, SOUTHAMPTON, Hampshire, SO18 1AD
Fabric Reference CQ Advantage. Colour: White.
Dimensions 120cm by full width (143cm)
Date Received 27.5.05
Pre-treatment None - the material was stated to be inherently flame retardant.
Conditioning BS 5438 : 1976, Clause 4.

TESTING

Following the pre-treatment described above, the material was conditioned and tested according to **Test 2 of BS 5438 : 1976 Method of test for flammability of vertically oriented textile fabrics and fabric assemblies subjected to a small igniting flame**, using a **15 second flame application time** and the results assessed according to the requirements of **BS 5867 : 1980 Specification for Fabrics for Curtains and Drapes, Part 2 : Flammability Requirements**. Testing was carried out on the face side of the fabric.

Specimen No.	WARP			WEFT		
	1	2	3	1	2	3
Flame reached an edge	No	No	No	No	No	No
Hole reached an edge	No	No	No	No	No	No
Flaming debris separated	No	No	No	No	No	No

It should be noted that the results may not apply to situations where there is a restricted air supply or prolonged exposure to intense heat as in a conflagration.

CONCLUSION

The sample received meets **BS 5867 : 1980 Specification for Fabrics for Curtains and Drapes, Part 2, Flammability Requirements, Type B and Clause 4.16 for Curtains and Drapes of the Guide to Fire Precautions in Existing Places of Entertainment and Like Premises (Home Office, 1994)**.

Mr J Leadbeater LL.B DTS

Technical Manager

END OF REPORT